

Hygiene conformity test

(Abridged version)

Air to air heat exchanger model H without equipment housing of Heatex AB, Sweden

Object of the test

At the request of **Heatex AB**, Tommarpsvägen 46, SE-231 65 Trelleborg, Sweden we have investigated whether their heat exchanger model H without equipment housing meet the hygiene requirements specified by **VDI 6022, sheet 1 (04/06)**, **VDI 3803 (10/02)**, **DIN 1946, part 4 (01/94)**, **ÖNORM H 6021 (09/03)** and **ÖNORM H 6020-1 (09/99)**, **SWKI VA104-01 (04/06)** and **SWKI 99-3 (03/04)** as well as **DIN EN 13779 (05/05)**. For this purpose a specimen heat exchanger model H without equipment housing of the above-mentioned type has been viewed at the test lab of ILH Berlin, Germany, and related technical literature (refer to our full report, chapter 2) has been appraised.

Summary of the test result

The examination of the above-mentioned sample equipment heat exchanger model H without equipment housing of Heatex AB, Sweden and the appraisal of both the literature made available to us and the reviewable documents have shown that the heat exchanger model H without equipment housing of Heatex, Sweden fully meet the hygiene requirements specified by the above mentioned standards (please refer to our full report).

**We hereby confirm that the heat exchanger model H without equipment housing
meets the requirements of the above-mentioned standards.**

Registration number: HKP/S/0042a./8/HE/0307/0310/MZ

This certification is valid until march, 2010



(Quality stamp with the inscription:
Institut für Lufthygiene, approved HVAC hygiene)

Expert in charge: Dr.-Ing. M. Möritz

Berlin, December 01, 2007