

Hygiene conformity test

(Abridged version)

**Rotation heat exchanger model B without equipment housing
of Heatex AB, Sweden****Object of the test**

At the request of **Heatex AB**, Tommarpsvägen 46, SE-231 65 Trelleborg, Sweden we have investigated whether their rotation heat exchanger model B without equipment housing meet the hygiene requirements specified by **VDI 6022, sheet 1 (04/06)**, **VDI 3803 (10/02)**, **ÖNORM H 6021 (09/03)**, **SWKI VA104-01 (04/06)** and **DIN EN 13779 (05/05)**. For this purpose a specimen heat exchanger without equipment housing of the above-mentioned type has been viewed on April 26th 2006 at the factory of Heatex AB, Sweden, and related technical literature (refer to our full report, chapter 2) has been appraised.

Summary of the test result

The examination of the above-mentioned sample equipment rotation heat exchanger model B without equipment housing of Heatex AB, Sweden and the appraisal of both the literature made available to us and the reviewable documents have shown that the rotation heat exchanger model B without equipment housing of Heatex, Sweden fully meet the hygiene requirements specified by VDI 6022, sheet 1 (04/06), VDI 3803 (10/02), ÖNORM H 6021 (09/03), SWKI VA104-01 (04/06) and DIN EN 13779 (05/05) (please refer to our full report).

We hereby confirm that the rotation heat exchanger model B without equipment housing of Heatex AB, Sweden meets the requirements of the above-mentioned standards.

Registration number: HKP/S/0042.1/5/HEA/0807/0710/MZ

This certification is valid until august, 2010



(Quality stamp with the inscription:
Institut für Lufthygiene, approved HVAC hygiene)

Expert in charge: Dr.-Ing. M. Möritz

Berlin, August 07, 2007